

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:55 pm

**PWS ID:** UTAH25124      **Name:** ALPINE COVE WATER SSD  
**Legal Contact:** ALPINE COVE WATER SSD      **Rating:** Approved  
DREW EMPEY      **Rating Date:** 05/04/1994  
**Address:** 13528 N ALPINE COVE      **Activity Status:** Active  
ALPINE, UT 84004  
**Phone Number:** 801-492-7861  
**City Served (Area):**  
**County:** UTAH COUNTY  
**System Type:** Community      **Last Inv Update:** 07/28/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 07/19/2010      **Total Dsgn Cap:**  
**Population:** 210      **Surveyor:** KATE JOHNSON      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day    Gal/Min

#### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	EMPEY, DREW		801-492-7861	801-921-4000	cdempey@gmail.com

#### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	63
			63    Total Svc Connections

#### Storage

**Total Storage:** 408,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	RESERVOIR #1	Ground	133,000 GAL	Concrete		A	
ST002	RESERVOIR #2	Ground	275,000 GAL	Concrete		A	

#### Distribution System

Pump Type	Total Dyn Head ft H2O    P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

#### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	JONES WELL	Active	WL	12	87 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS002	PETERSON WELL	Active	WL	12	52 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS003	PACK WELL	Active	WL		83 GPM	140 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.